

# HU-1 Cistern

## BMP MAINTENANCE FACT SHEET FOR STRUCTURAL BMP HU-1 CISTERN

**Cisterns** are containers that capture runoff (typically rooftop runoff) and store it for future use such as irrigation or alternative grey water between storm events. Cisterns can be aboveground or below ground systems. Typical cistern components include:

- Storage container, barrel or tank for holding captured flows
- Inlet and associated valves and piping
- Outlet and associated valves and piping
- Overflow outlet
- Access riser or tank serviceway (i.e., access for underground and above-ground cisterns)
- Optional pump
- Optional first flush diverters
- Optional debris screen or pretreatment BMP (e.g., roof drain filter, drainage inlet insert)
- Optional roof, supports, foundation, level indicator, and other accessories

### Normal Expected Maintenance

Cisterns can be expected to accumulate sediment and debris that is small enough to pass through the inlet into the storage container. Larger debris such as leaves or trash may accumulate at the inlet. While the storage container is generally a permanent structure, ancillary parts including valves, piping, screens, level indicators, and other accessories will wear and require occasional replacement. Maintenance of a cistern generally involves: removing accumulated sediment and debris from the inlet and storage container on a routine basis; and replacement of ancillary parts on an as-needed basis. A summary table of standard inspection and maintenance indicators is provided within this Fact Sheet. If the system as a whole includes a pump or other electrical equipment, maintenance of the equipment shall be based on the manufacturer's recommended maintenance plan.

### Non-Standard Maintenance or BMP Failure

If any of the following scenarios are observed, the BMP is not performing as intended to protect downstream waterways from pollution and/or erosion. Corrective maintenance, increased inspection and maintenance, BMP replacement, or a different BMP type will be required.

- The inlet is found to be obstructed at every inspection such that storm water bypasses the cistern. The cistern is not functioning properly if it is not capturing storm water. This would require addition of ancillary features to protect the inlet, or pretreatment measures within the watershed draining to the cistern to intercept larger debris, such as screens on roof gutters, or drainage inserts within catch basins. Increase the frequency of inspection until the issue is resolved.
- Accumulation of sediment within one year is greater than 25% of the volume of the cistern. This means the sediment load from the tributary drainage area has diminished the storage volume of the cistern and the cistern will not capture the required volume of storm water. This would require pretreatment measures within the tributary area draining to the cistern to intercept sediment.
- The cistern is not drained between storm events. If the cistern is not drained between storm events, the storage volume will be diminished and the cistern will not capture the required volume of storm water from subsequent storms. This would require implementation of practices onsite to drain and use the stored water, or a different BMP if onsite use cannot be reliably sustained.

# HU-1 Cistern

<b>SUMMARY OF STANDARD INSPECTION AND MAINTENANCE FOR HU-1 CISTERN</b>		
<p>The property owner is responsible to ensure inspection, operation and maintenance of permanent BMPs on their property unless responsibility has been formally transferred to an agency, community facilities district, homeowners association, property owners association, or other special district.</p> <p>Maintenance frequencies listed in this table are average/typical frequencies. Actual maintenance needs are site-specific, and maintenance may be required more frequently. Maintenance must be performed whenever needed, based on maintenance indicators presented in this table. The BMP owner is responsible for conducting regular inspections to see when maintenance is needed based on the maintenance indicators. During the first year of operation of a structural BMP, inspection is recommended at least once prior to August 31 and then monthly from September through May. Inspection during a storm event is also recommended. After the initial period of frequent inspections, the minimum inspection and maintenance frequency can be determined based on the results of the first year inspections.</p>		
<b>Threshold/Indicator</b>	<b>Maintenance Action</b>	<b>Typical Inspection and Maintenance Frequency</b>
Accumulation of sediment, litter, or debris at the inlet	Remove and properly dispose of accumulated materials.	<ul style="list-style-type: none"> <li>Inspect monthly and after every 0.5-inch or larger storm event.</li> <li>Remove any accumulated materials found at each inspection.</li> </ul>
Outlet blocked	Clear blockage.	<ul style="list-style-type: none"> <li>Inspect monthly and after every 0.5-inch or larger storm event.</li> <li>Remove any accumulated materials found at each inspection.</li> </ul>
Accumulation of sediment, litter, or debris in the storage container	Remove and properly dispose of accumulated materials.	<ul style="list-style-type: none"> <li>Inspect monthly. If the BMP is 25% full* or more in one month, increase inspection frequency to monthly plus after every 0.1-inch or larger storm event.</li> <li>Remove materials annually (minimum), or more frequently when BMP is 25% full* (or at manufacturer threshold if manufacturer threshold is less than 25% full*) in less than one year, or if accumulation blocks outlet</li> </ul>
Standing water in storage container between storm events outside of normal use timeframe for the stored water. Normal use timeframe is 36 to 96 hours following a storm event depending on the purpose and design of the cistern.	<p>Use the water as intended, or disperse to landscaping.</p> <p>Implement practices onsite to drain and use the stored water.</p> <p>Contact the [City Engineer] to determine a solution if onsite use cannot be reliably sustained.</p>	<ul style="list-style-type: none"> <li>Inspect monthly and after every 0.5-inch or larger storm event. If standing water is observed, increase inspection frequency to after every 0.1-inch or larger storm event.</li> <li>Maintenance when needed.</li> </ul>

\*"25% full" is defined as ¼ of the depth from the design bottom elevation to the crest of the outflow structure (e.g., if the height to the outflow opening is 12 inches from the bottom elevation, then the materials must be removed when there is 3 inches of accumulation – this should be marked on the outflow structure)

# HU-1 Cistern

SUMMARY OF STANDARD INSPECTION AND MAINTENANCE FOR HU-1 CISTERN (Continued from previous page)		
Threshold/Indicator	Maintenance Action	Typical Inspection and Maintenance Frequency
Presence of mosquitos/larvae  For images of egg rafts, larva, pupa, and adult mosquitos, see <a href="http://www.mosquito.org/biology">http://www.mosquito.org/biology</a>	If mosquitos/larvae are observed: first, immediately remove any standing water by using the water as intended for irrigation or alternative grey water, or by dispersing to landscaping; second, check cistern outlet for blockage and clear blockage if applicable to restore drainage; third, install barriers such as screens that prevent mosquito access to the storage container.	<ul style="list-style-type: none"> <li>• Inspect monthly and after every 0.5-inch or larger storm event. If mosquitos are observed, increase inspection frequency to after every 0.1-inch or larger storm event.</li> <li>• Maintenance when needed.</li> </ul>
Leaks or other damage to ancillary parts including valves, piping, screens, level indicators, and other accessories	Repair or replace as applicable.	<ul style="list-style-type: none"> <li>• Inspect twice per year.</li> <li>• Maintenance when needed.</li> </ul>
Leaks or other damage to storage container	Repair or replace as applicable.	<ul style="list-style-type: none"> <li>• Inspect twice per year.</li> <li>• Maintenance when needed.</li> </ul>
Cistern leaning or unstable, damage to roof, supports, anchors, or foundation	Make repairs as appropriate to correct the problem and stabilize the system.	<ul style="list-style-type: none"> <li>• Inspect twice per year.</li> <li>• Maintenance when needed.</li> </ul>

## References

American Mosquito Control Association.

<http://www.mosquito.org/>

California Storm Water Quality Association (CASQA). 2003. Municipal BMP Handbook.

<https://www.casqa.org/resources/bmp-handbooks/municipal-bmp-handbook>

County of San Diego. 2014. Low Impact Development Handbook.

<http://www.sandiegocounty.gov/content/sdc/dpw/watersheds/susmp/lid.html>

San Diego County Copermittees. 2016. Model BMP Design Manual, Appendix E, Fact Sheet HU-1.

[http://www.projectcleanwater.org/index.php?option=com\\_content&view=article&id=250&Itemid=220](http://www.projectcleanwater.org/index.php?option=com_content&view=article&id=250&Itemid=220)

# HU-1 Cistern

Page Intentionally Blank for Double-Sided Printing

# HU-1 Cistern

Date:	Inspector:	BMP ID No.:
Permit No.:	APN(s):	
Property / Development Name:		Responsible Party Name and Phone Number:
Property Address of BMP:		Responsible Party Address:

INSPECTION AND MAINTENANCE CHECKLIST FOR HU-1 CISTERN PAGE 1 of 4			
Threshold/Indicator	Maintenance Recommendation	Date	Description of Maintenance Conducted
Accumulation of sediment, litter, or debris at the inlet  Maintenance Needed? <input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A	<input type="checkbox"/> Remove and properly dispose of accumulated materials  <input type="checkbox"/> If the inlet is found to be obstructed at every inspection, add features to protect the inlet, or pretreatment measures within the watershed  <input type="checkbox"/> Other / Comments:		
Outlet blocked  Maintenance Needed? <input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A	<input type="checkbox"/> Clear blockage  <input type="checkbox"/> Other / Comments:		

# HU-1 Cistern

Date:	Inspector:	BMP ID No.:
Permit No.:	APN(s):	

INSPECTION AND MAINTENANCE CHECKLIST FOR HU-1 CISTERN PAGE 2 of 4			
Threshold/Indicator	Maintenance Recommendation	Date	Description of Maintenance Conducted
<p>Standing water in storage container between storm events outside of normal use timeframe for the stored water. Normal use timeframe is 36 to 96 hours following a storm event depending on the purpose and design of the cistern.</p> <p>Maintenance Needed?</p> <p><input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A</p>	<p><input type="checkbox"/> Use the water as intended, or disperse to landscaping</p> <p><input type="checkbox"/> Implement practices onsite to drain and use the stored water</p> <p><input type="checkbox"/> Contact the [City Engineer] to determine a solution if onsite use cannot be reliably sustained</p> <p><input type="checkbox"/> Other / Comments:</p>		
<p>Presence of mosquitos/larvae</p> <p>For images of egg rafts, larva, pupa, and adult mosquitos, see <a href="http://www.mosquito.org/biology">http://www.mosquito.org/biology</a></p> <p>Maintenance Needed?</p> <p><input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A</p>	<p><input type="checkbox"/> Use the water as intended, or disperse to landscaping</p> <p><input type="checkbox"/> Install barriers such as screens that prevent mosquito access to the storage container</p> <p><input type="checkbox"/> Other / Comments:</p>		

# HU-1 Cistern

Date:	Inspector:	BMP ID No.:
Permit No.:	APN(s):	

INSPECTION AND MAINTENANCE CHECKLIST FOR HU-1 CISTERN PAGE 3 of 4			
Threshold/Indicator	Maintenance Recommendation	Date	Description of Maintenance Conducted
<p>Accumulation of sediment, litter, or debris in the storage container – to be cleared once per year or when debris accumulation is 25% of the total container volume, or accumulation blocks outlet, whichever is more frequent</p> <p>Maintenance Needed?</p> <p><input type="checkbox"/> YES  <input type="checkbox"/> NO  <input type="checkbox"/> N/A</p>	<p><input type="checkbox"/> Remove and properly dispose of accumulated materials</p> <p><input type="checkbox"/> If accumulation of sediment within one year is &gt;25% of the volume of the cistern, add pretreatment measures within the watershed</p> <p><input type="checkbox"/> Other / Comments:</p>		
<p>Leaks or other damage to storage container</p> <p>Maintenance Needed?</p> <p><input type="checkbox"/> YES  <input type="checkbox"/> NO  <input type="checkbox"/> N/A</p>	<p><input type="checkbox"/> Repair or replace as applicable</p> <p><input type="checkbox"/> Other / Comments:</p>		

# HU-1 Cistern

Date:	Inspector:	BMP ID No.:
Permit No.:	APN(s):	

INSPECTION AND MAINTENANCE CHECKLIST FOR HU-1 CISTERN PAGE 4 of 4			
Threshold/Indicator	Maintenance Recommendation	Date	Description of Maintenance Conducted
Leaks or other damage to ancillary parts including valves, piping, screens, level indicators, and other accessories  Maintenance Needed?  <input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A	<input type="checkbox"/> Repair or replace as applicable  <input type="checkbox"/> Other / Comments:		
Cistern leaning or unstable, damage to roof, supports, anchors, or foundation  Maintenance Needed?  <input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A	<input type="checkbox"/> Make repairs as appropriate to correct the problem and stabilize the system  <input type="checkbox"/> Other / Comments:		